

2 WAY PILLAR FIRE HYDRANT



SPECIFICATION

Title	Description
Body	Ductile iron / Cast iron
Pressure rating	Low Pressure Landing Valves
Working pressure	16bar
Test pressure	24bar
Finishing	Red or yellow
Applicable standards	BS 336:2010 - BS 750
Inlet size	BS instantaneous male copper alloy BS 1982
Outlet size	Flange 4"/6" PN16